

Mandatory Language for Monitoring/Reporting Violation

Failure to Submit a Disinfectant Level Quarterly Operating Report (DLQOR)

MONITORING, ROUTINE (dbp), MAJOR/CHLORINE

The Marbridge Foundation water system PWS ID 2270039 has violated the monitoring/reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public Water Systems are required to properly disinfect water before distribution, maintain acceptable residuals within the distribution system and report the results of that monitoring to TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This violation occurred in the monitoring period Quarter 3 of 2024.

Marbridge was monitoring the water residuals, but the results were not submitted to TCEQ. The monitoring results have since been submitted to TCEQ.

If you have any questions regarding this matter, you may contact Michael O'Shieles at 512-282-1144.

POSTED 1-16-2025

Disinfectant Level Quarterly Operating Report (DLQOR)

For All Groundwater or Purchased-Water Public Water Systems

Select Quarter:	Quarter 3 (July, August, September) ▼	Year:	2024
PWS Name:	Marbridge Foundation	PWS ID:	2270039
Type of Disinfectant Used in Distribution System:	Chlorine (Free)		▼

First Month of Quarter: Monthly Summary

Month: July ▼

Was the PWS active this month? ☒ Yes ☐ No

Average of all disinfectant residuals:		Number of residuals collected:	Number of residuals below minimum:	Number of NO residuals:
0.76	mg/L	9 Count	Readings 0.0 %	Readings 0.0 %

Second Month of Quarter: Monthly Summary

Month: August ▼

Was the PWS active this month? ☒ Yes ☐ No

Average of all disinfectant residuals:		Number of residuals collected:	Number of residuals below minimum:	Number of NO residuals:
0.75	mg/L	9 Count	Readings 0.0 %	Readings 0.0 %

Third Month of Quarter: Monthly Summary

Month: September ▼

Was the PWS active this month? ☒ Yes ☐ No

Average of all disinfectant residuals:		Number of residuals collected:	Number of residuals below minimum:	Number of NO residuals:
0.78	mg/L	10 Count	Readings 0.0 %	Readings 0.0 %

Quarterly Summary and Certification

Average of all disinfectant residuals for this quarter		LOWEST disinfectant residual for this quarter	HIGHEST disinfectant residual for this quarter
0.76	mg/L	0.40 mg/L	1.10 mg/L

☒ I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Name: Michael O'Shieles

Date: 2024 01 16

Signature: 

Title and Phone Number: Director of Facilities (512) 282-1144

Water Operator License Number: WO0037133

Email: moshieles@marbridge.org

Complete this form for the previous quarter at the beginning of April, July, October, and January; and submit in time for it to be received by the TCEQ by the 10th of the month. Always print and sign form and keep a copy with your records for TCEQ review during onsite investigations.

Sign the DLQOR and mail to:

Certified Mail: TCEQ/DWSS MC-155, Attn: DLQOR, 12100 Park 35 Circle, Bldg F, Austin, TX 78753-1808

Regular Mail: TCEQ/DWSS MC-155, Attn: DLQOR, P.O. Box 13087, Austin, TX 78711-3087